



DISCLAIMER: UNIVERSALPEGASUS INTERNATIONAL MAKES NO WARRANTY (EXPRESSED, IMPLIED OR OTHERWISE) THAT THE INFORMATION CONTAINED HEREIN IS ACCURATE OR COMPLETE AS TO ANY AND ALL SUBSURFACE CONDITIONS AND CONFORMATION. ANY RELIANCE CONTRACTOR PLACES ON THE INFORMATION CONTAINED HEREIN AS TO SUCH CONDITIONS, IS DONE SO AT ITS OWN RISK AND EXPENSE. IT IS THE SOLE RESPONSIBILITY OF THE CONTRACTOR TO CONTACT THE STATE "ONE CALL" SYSTEM PRIOR TO ANY EXCAVATION.

SURVEY DATA		STATIONING	
MATCHLINE 4250+00		MATCHLINE 4250+00	MATCHLINE 4300+00

ENGINEERING DATA		MATERIAL	
MATCHLINE 4250+00		MATCHLINE 4250+00	MATCHLINE 4300+00

ENVIRONMENTAL DATA		STATIONS	
MATCHLINE 4250+00		MATCHLINE 4250+00	MATCHLINE 4300+00

BILL OF MATERIALS		MISCELLANEOUS MATERIALS		TYPICAL DRAWINGS		GENERAL INFORMATION	
ITEM NO.	QTY	UOM	REQ'N NUMBER	MATERIAL NUMBER	DESCRIPTION	DWG/FIELD BOOK NO.	TITLE
1	5000	FT			30" O.D. x 0.429" W.T., API 5L, X70, PSL2, DSAW, 14-16 MILS FBE	21040-510-TYP-20001	CATHODIC PROTECTION STD. SINGLE POINT TEST STATION, TYPE 1
2	1	EA			PIPELINE MARKERS	21040-510-TYP-20002	CATHODIC PROTECTION STD. FOREIGN PIPELINE CROSSING TEST STATION, TYPE 2
3	0	EA			WARNING SIGNS	21040-510-TYP-20028	TYPICAL OPEN CUT / BORE
4	0	EA			CP TEST STATION TYPE 1	21040-510-TYP-20112	CONTINUOUS CONCRETE COATING STANDARD FOR 36" / 30" PIPELINE
5	0	EA			CP TEST STATION TYPE 2	21040-510-TYP-20113	TYPICAL SADDLE BAG WEIGHTS
6	0	EA			AERIAL MARKERS	21040-510-TYP-20114	WARNING SIGN DETAIL
7	0	EA			ANODE BED DEEP WELL	21040-510-TYP-20115	AERIAL MARKER INSTALLATION DETAIL
8	0	EA				21040-510-TYP-20116	AERIAL MARKER DETAIL
9	0	EA				21040-510-TYP-20117	TYPICAL PIPELINE MARKER ASSEMBLY
10	0	EA				21040-510-TYP-20118	PIPELINE MARKER "WARNING" DECAL

FITTINGS SUMMARY		CONTINUOUS CONCRETE COATING		PIPE COATING DATA		PIPE ASSEMBLIES	
ITEM NO.	QTY	UOM	REQ'N NUMBER	MATERIAL NUMBER	DESCRIPTION	PIPE COATING: 14 MIL MINIMUM FBE AND 24 MIL MINIMUM ARO	INTERNAL COATING (YES/NO): NO
1	0	EA					
2	0	EA					
3	0	EA					

REVISIONS		APPROVALS	
NO.	DESCRIPTION	DATE	REV BY
1	IFC (UPDATE ENV., RE-ROUTES, FOOT-PRINT)	2016-04-08	MB MJ
0	ISSUED FOR CONSTRUCTION	2015-12-15	MB MJ

APPROVAL		COMPANY	
ENVIRONMENTAL	LAND	UNIVERSALPEGASUS INTERNATIONAL	FLORIDA SOUTHEAST CONNECTION

FLORIDA SOUTHEAST CONNECTION PROJECT			
STA: 4250+00 TO 4300+00	DISCIPLINE: 03	FLORIDA SOUTHEAST CONNECTION ALIGNMENT SHEET OKEECHOBEE COUNTY, FLORIDA	
SCALE: 1" = 200'	21040-510-ALS-00090	REV. 1	SHEET 90