

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Bevel Creek Lift Station Pump

DATE OF MEETING: September 8, 2015

BUDGET IMPACT: \$38,930.50

FUNDING SOURCE

- Annual
- Capital
- N/A

- Regular Meeting
- Work Session
- Recommendation
- Policy/Discussion
- Report
- Other

COUNTY ACTION REQUESTED ON: Bevel Creek Lift Station Pump

HISTORY, FACTS AND ISSUES: The Bevel Creek lift station is a triplex station that delivers over 60% of the wastewater flow to Land Application System. Currently, the county is running on two pumps at this station. The pump that is out of service is a Flygt pump that was built in 1992. Staff received a quote to repair this pump for \$40,063.50. Two additional quotes were received for a new Flygt pump for \$58,097.10 and a new Wilo pump for \$38,930.50. After considerable research staff recommends the purchase of the Wilo pump at the Bevel Creek lift station.


OPTIONS: (1) Approve the purchase of Wilo pump
(2) Board's Pleasure

RECOMMENDED ACTION: Approve the purchase of Wilo pump

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:



County Manager

Action Taken By Board: _____