



PRODUCT REPAIR / SERVICE ESTIMATE

Estimate #: R2019-SAV-0137

Date: 11/5/2019

Page 1 of 5

Tag #: 4169

JobName: Hart Road

Customer Information

Company Name: LOWNDES CNTY UTILITES DEPT

Contact: Dale

Address

Telephone:

PO BOX 1349

Telephone:

VALDOSTA GA31603

Fax:

Email:

Following is an estimate prepared for you regarding the repair of your Flygt pump.

Product Identification

Product Number: 3201.180-5909

Serial Number: 3201.180-9240100

Model: 3201

Impeller Code: 264

HP: 40

Volts: 400

Phases: 3

Inspection Information

Inspected By:

Motor Data: Wire Configuration: U1:Red V1:Black W1:White

Megger to ground: R 550 B 550 W 550

Sensors:

Resistance through cable: RB 0.62 RW 0.65 BW 0.68

FLS

Stator Condition: Unusable

CLS

Shaft Condition: Good

KLIX

Oil Condition: Unusable

Bearing

Inspection Plugs:

Cable

Hydraulic: Impeller/Propeller Condition: Unusable

Cable Condition: Unusable

Volute Condition: Unusable

Cable Length: 30'

Flygt Products

128 A Airport Park Drive , Garden City GA 31408

PH: (912) 966-1577

FX: (912) 966-1579

