

1.09 SYSTEM SERVICE CONTRACT

- A. The supplier of the standby power system shall provide a copy of and make available to the owner his standard service contract which, at the owner's option, may be accepted or refused. This contract will accompany any documents, drawings, catalog cuts, specification sheets, wiring, or outline drawings, etc. Submitted for approval to the designing engineer. The contract shall be for the complete power system.

1.10 WARRANTY

- A. The complete standby electrical system furnished under this Section shall be guaranteed against defective parts and workmanship under terms of the manufacturer's and dealer's standard warranty. But, in no event shall it be for a period of less than five (5) years or 3000 hours from date of final testing and acceptance of the system and shall include labor, parts and travel time for necessary repairs at the job site. Warranty information shall be submitted along with construction site test data sheets. This information shall list starting and ending dates and who is to be contacted for warranty service.

END OF SECTION 16190

EDC#