LOWNDES COUNTY BOARD OF COMMISSIONERS COMMISSION AGENDA ITEM

SUBJECT: Foxborough Lift Station Pump	
	Work Session/Regular Session
DATE OF MEETING: September 22, 2020	
PLID CET INADA CT. CAA. 247 CO	
BUDGET IMPACT: \$41,217.60	
FUNDING SOURCE:	
(X) Annual	
() Capital	
() N/A	
() SPLOST	
() TSPLOST	

COUNTY ACTION REQUESTED ON: Foxborough Lift Station Pump

HISTORY, FACTS AND ISSUES: Due to excessive ragging and the age of the pumps, staff is recommending that one of the pumps at the Foxborough lift station be replaced with a new N-impeller pump. Staff received a quote from Xylem for an 85hp pump for \$41,217.60. Staff recommends purchasing the new pump for the Foxborough Lift Station from Xylem, Inc. for \$41,217.60.

OPTIONS: 1. Approve the purchase of a new pump for the Foxborough Lift Station

2. Board's pleasure

RECOMMENDED ACTION: Approve

<u>DEPARTMENT</u>: Utilities <u>DEPARTMENT HEAD</u>: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: