

Attachment A

GEORGIA ENVIRONMENTAL PROTECTION DIVISION
WATERSHED COMPLIANCE PROGRAM
2 MLK JR. DR. S.E., SUITE 1152
ATLANTA, GEORGIA 30334

Lowndes County Alapaha Plantation S/D Water System WSID# GA1850274

HAA5 MCL 0.060 mg/L
TTHM MCL 0.080 mg/L

HAA5/TTHM MCL Violations
July 2019 to March 31, 2021

Compliance Period	Sample Point	MCL Result (Running Annual Average)
3 rd quarter 2019 (07/01/2019 - 09/30/2019)	501	HAA5- 0.062 mg/L
3 rd quarter 2019 (07/01/2019 - 09/30/2019)	502	HAA5- 0.068 mg/L TTHM- 0.088 mg/L
4 th quarter 2019 (10/01/2019 - 12/31/2019)	501	HAA5- 0.080 mg/L TTHM- 0.092 mg/L
4 th quarter 2019 (10/01/2019 - 12/31/2019)	502	HAA5- 0.101 mg/L TTHM- 0.126 mg/L
1 st quarter 2020 (01/01/2020 - 03/31/2020)	501	HAA5- 0.110 mg/L TTHM- 0.122 mg/L
1 st quarter 2020 (01/01/2020 - 03/31/2020)	502	HAA5- 0.126 mg/L TTHM- 0.150 mg/L
2 nd quarter 2020 (04/01/2020 - 06/30/2020)	501	HAA5- 0.128 mg/L TTHM- 0.139 mg/L
2 nd quarter 2020 (04/01/2020 - 06/30/2020)	502	HAA5- 0.134 mg/L TTHM- 0.150 mg/L
3 rd quarter 2020 (07/01/2020 - 09/30/2020)	501	HAA5- 0.155 mg/L TTHM- 0.172 mg/L
3 rd quarter 2020 (07/01/2020 - 09/30/2020)	502	HAA5- 0.157 mg/L TTHM- 0.167 mg/L
4 th quarter 2020 (10/01/2020 - 12/31/2020)	501	HAA5- 0.183 mg/L TTHM- 0.192 mg/L
4 th quarter 2020 (10/01/2020 - 12/31/2020)	502	HAA5- 0.176 mg/L TTHM- 0.169 mg/L
1 st quarter 2021 (01/01/2021 - 03/31/2021)	501	HAA5- 0.202 mg/L TTHM- 0.187 mg/L
1 st quarter 2021 (01/01/2021 - 03/31/2021)	502	HAA5- 0.196 mg/L TTHM- 0.175 mg/L