

EXHIBIT A
DEPICTION OF EQUIPMENT IN PREMISES AND LICENSE AREA
LOWNDES COUNTY

- 1: Existing 3-ph UG Primary
- 2: Extend UG primary from existing transformer
- 3: NEW 150 KVA 480V Padmount xfrm
- 4: New Meter Point & Secondary Electrical, external disconnect 480v/208v stepdown transformer.
- 5: (1) DC Fast Chargers configuration for up to 62.5 kw Output and (1) Level 2 Dural Port

