

6/12/23 Draft

Formatted: Font: Century

Formatted: Right

Formatted: Font: Century

~~2006 International Fire Code with Georgia Amendments;~~

Formatted: Indent: Left: 1", No bullets or numbering, Tab stops: Not at 1.25"

~~K. 2006 International Residential Code with Georgia Amendments;~~

Formatted: No bullets or numbering, Tab stops: Not at 1.25"

~~L. 1997 Georgia Accessibility Code;~~

Formatted: Tab stops: Not at 1.25"

~~M.A. 2000 Life Safety Code~~

1.08.02 Responsibility for Interpretations

C. Should the enforcement of a building or construction code listed in Section 1.07.04 create a conflict Table 1.08.02(C) shall govern the primary and supplemental enforcement of that building or construction code:

Table 1.08.02(C). Code Reference Guide

Area	Primary Code	Supplement Code
Occupancy Classification	LSC	IBC
Building Construction Types Including allowable height, allowable building areas, and the requirements for sprinkler protection related to minimum building construction types.	IBC	LSC
Means of Egress	LSC	NONE
Standpipes	IBC	IFC
Interior Finish	LSC	NONE
HVAC Systems	IMC	NONE
Vertical Openings	LSC	NONE
Sprinkler Systems minimum construction standard	LSC	NONE
Fire Alarm Systems	LSC	NONE
Smoke Alarms and Smoke Detection Systems	State Statute and LSC	NONE
Portable Fire Extinguishers	IFC	NONE

Formatted: Left

Formatted: Font: Century

Field Code Changed