

4.8.6.3 PLUMBING

- (a) Underground Inspection: To be made after trenches or ditches are excavated, piping installed, and before any backfill is put in place.
- (b) Rough-In Inspection: To be made after the roof, framing, fireblocking and bracing are in place and all soil, waste and vent piping is complete, and prior to this installation of wall or ceiling membranes.
- (c) Final Inspection: To be made after the building is complete, all plumbing fixtures are in place and properly connected, and the structure is ready for occupancy.
- (d) Note: See Section 311 of the International Plumbing Code for required tests.

4.8.6.4 MECHANICAL

- (a) Underground Inspection: To be made after trenches or ditches are excavated, underground duct and fuel piping installed, and before any backfill is put in place.
- (b) Rough-In Inspection: To be made after the roof, framing, fire blocking and bracing are in place and all ducting, and other concealed components are complete, and prior to the installation of wall or ceiling membranes.
- (c) Final Inspection: To be made after the building is complete, the mechanical system is in place and properly connected, and the structure is ready for occupancy.

4.8.6.5 GAS

- (a) Rough Piping Inspection: To be made after all new piping authorized by the permit has been installed, and before any such piping has been covered or concealed or any fixtures or gas appliances have been connected.
- (b) Final Piping Inspection: To be made after all piping authorized by the permit has been installed and after all portions which are to be concealed by plastering or otherwise have been so concealed, and before any fixtures or gas appliances have been connected. This inspection shall include a pressure test.
- (c) Final Inspection: To be made on all new gas work authorized by the permit and such portions of existing systems as may be affected by new work or any changes in order to ensure compliance with all the requirements of the Construction Codes and to assure that the installation and construction of the gas system is in accordance with reviewed plans.