

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Bevel Creek Pump Repair

DATE OF MEETING: December 10, 2024

BUDGET IMPACT: \$32,306.82

Work
Session/Regular
Session

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: Bevel Creek Pump Repair

HISTORY, FACTS AND ISSUES: The Bevel Creek lift station is a triplex station with 160hp pumps near the end of our trunk line before the LAS. One of the pumps began running high amps and tripping the breaker. The pump was pulled and sent to Xylem for repairs. After analyzing the pump, it needs a complete rebuild for \$32,306.82. The price for a new pump is \$77,626.15. Staff recommends approval for the pump to be rebuilt for \$32,306.82.

OPTIONS: 1. Approve
2. Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: