

# LNG Emergency Response

- LNG – the next priority
- High hazard flammable trains (HHFT)
- NGLs associated with liquefaction facilities
- Alaska and Florida LNG Training completed

- ❖ Cannot cap off a leak or interact with container
- ❖ Immediate Evacuation of area and securing of facilities
- ❖ Cannot put water on a cryogenic release
- ❖ LNG must gas off naturally, and ignition sources eliminated